Building Services, Room 201 City-County Building 300 West Ash · P.O. Box 736 Salina, Kansas 67402-0736



TELEPHONE · (785) 309-5715

FAX · (785) 309-5713

TDD · (785) 309-5747

WEBSITE · www.salina-ks.gov

## Emergency Escape and Rescue Openings Inspection Checklist

**DRAFT** 

Addre	ess:		Contrac	tor:		Permit #
The following checklist is not all-inclusive. Other code related requirements may be included in this inspection						
OK Yes No	n/a	Verify that window loc with approved plan.	ation conforr	ms	OK Yes No n/a	Verify that the minimum horizontal area of the window well is 9' square, with a minimum horizontal projection and width of 36". IRC sec R310.2
OK Yes No	n/a	Verify minimum five s openable area. IRC sec exception			OK Yes No n/a	Verify that any bars, grills or screens can be released from the inside with out a special key or tool. IRC sec R301.1.4
OK Yes No	n/a	Verify minimum 24" n height and 20" net ope IRC sec R310.1.2			OK Yes No n/a	Verify permanent ladders installed. Ladders to be a minimum 12" wide with rungs no more that 18" apart for full depth of window well and no less than 3" from the wall. See local Administrative Interpretation for wood steps. IRC sec R310.2.1
OK Yes No	n/a	Verify that bottom edgeno more than 44" above floor. IRC sec R310.1			OK Yes No n/a	All other special conditions complied with. (e.g. Planning Department requirements for flood fringe lots)
OK Yes No	n/a				OK Yes No n/a	
Notes:				1		
Date			Inspector			